

Energy performance certificate (EPC)

13 Walker Terrace Bensham Road Bensham GATESHEAD NE8 1EB	Energy rating <h1>D</h1>	Valid until: 28 February 2033 <hr/> Certificate number: 4152-6808-4059-1418-7646
--	-----------------------------	---

Property type Non-residential Institutions: Education


Total floor area 374 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is D.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built 29 | B

If typical of the existing stock 117 | E

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO ₂ /m ² per year)	30.71
Primary energy use (kWh/m ² per year)	194

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/4901-9672-1127-7492-1462\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	George Smith
Telephone	07756529827
Email	gsmith0_1@hotmail.com

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO000595
Telephone	0330 124 9660
Email	certification@stroma.com

Assessment details

Employer	DG Surveys
Employer address	14 Markington Drive, Ryhope, Sunderland SR2 0LB
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	24 February 2023
Date of certificate	1 March 2023
