# **Energy performance certificate (EPC)**

First Floor
7 Mount Terrace
SOUTH SHIELDS
NE33 1PN

Energy rating
Certificate
number:

Valid until:
15 September 2034
1420-4460-5258-1597-1827

Property type

Restaurants and Cafes/Drinking
Establishments/Takeaways

Total floor area


240 square metres

### Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

## **Energy rating and score**

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

## How this property compares to others

Properties similar to this one could have ratings:

If newly built

If typical of the existing stock

89 D

22 A

## Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Air Conditioning
Assessment level	3
Building emission rate (kgCO2/m2 per year)	52
Primary energy use (kWh/m2 per year)	390

## **Recommendation report**

Guidance on improving the energy performance of this property can be found in the recommendation report (/energy-certificate/9975-4127-8775-9231-8551).

#### Who to contact about this certificate

#### **Contacting the assessor**

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	George Smith
Telephone	07756 529 827
Email	gsmith0_1@hotmail.com

### Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/015409
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

#### About this assessment

DG Surveys
14 Markington Drive, Ryhope, Sunderland SR2 0LB
The assessor is not related to the owner of the property.
13 September 2024
16 September 2024